

C O N F I D E N T I A L

REAL ESTATE AND CONSTRUCTION DIVISION WEEKLY REPORT
FOR PERIOD ENDING 16 MAY 1984

1. Progress Report Tasks Assigned by the DCI/DDCI:

None

2. Items or Events of Major Interest that have Occurred During the Preceding Week:

25X1

C O N F I D E N T I A L

C O N F I D E N T I A L

REAL ESTATE AND CONSTRUCTION DIVISION WEEKLY REPORT FOR PERIOD
ENDING 16 MAY 1984

e. Ames, Key and Chamber of Commerce Parking Controls - A draft lease for the parking area in the Key Building has been prepared by RECD and reviewed by Logistics & Procurement Law Division. A meeting to commence negotiations with the lessor for this site will be held on 18 May 1984.

25X1 The contract architect has prepared drawings on the Key and Ames Buildings, and these drawings have been forwarded to the Chief, Domestic Security Division, for the Office of Security's concurrence. [REDACTED]

25X1 f. Electrical Fire Damage to Existing AHU in GJ-56 - On 12 May 1984, while relocating the existing air handling unit (AHU) in GJ-56 as part of the ETECS expansion, electrical fire damage was discovered in the unit. The fire damage had apparently occurred at an earlier date, but was not discovered or reported. Damage was apparent in the form of melted insulation in the control wiring harness and at control relay contacts. After surveying the existing damage, it was determined that the unit was unsafe to operate and emergency repairs were made on the unit by [REDACTED] of RECD. The unit was rewired for safe operation and was back on line by 1600 hours on 12 May 1984.

25X1 In order to ensure continued safe operation of the unit, a factory representative will be called to check the unit for proper operation and to rewire the unit as required. [REDACTED]

25X1 3. Significant Events Anticipated During the Coming Week:

25X1 None

C O N F I D E N T I A L